

[1]

EU-TYPE EXAMINATION CERTIFICATE



[2]

Equipment or Protective System intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

[3]

EU-Type Examination Certificate Number: **DEMKO 17 ATEX 1923X Rev. 2**

[4]

Product: **Servo Motors M43X-XXXX-BXXX, M43X-XXXX-CXXX, M44X-XXXX-BXXX, M44X-XXXX-CXXX, M46X-XXXX-BXXX, M46X-XXXX-CXXX**

[5]

Manufacturer: **Elwood Corporation**

[6]

Address: **2701 N. Green Bay Road, Racine, WI 53404 USA**

[7]

This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

[8]

UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Council Directive 2014/34/EU of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. **US/UL/ExTR17.0088/02.**

[9]

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018 EN 60079-31:2014 IEC 60079-31, 3rd Edition (2022-01)

[10]

If the sign "X" is placed after the certificate number, it indicates that the product is subject to special conditions for safe use specified in the schedule to this certificate.

[11]

This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by the certificate.

[12]

The marking of the product shall include the following:

 **II 2 D Ex tb IIIC T135°C Db IP6X (Models M43X and M46X)**

 **II 2 D Ex tb IIIC T115°C Db IP6X (Models M44X)**

Certification Manager

Thomas Wilson

This is to certify that the sample(s) of the Product described herein ("Certified Product") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured product. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all product to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2017-09-13

Re-issued: 2023-06-30

Notified Body

UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark
Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com

Accredited by DANAK under registration number 7011 to certification of products.



[13]

[14]

Schedule

EU-TYPE EXAMINATION CERTIFICATE No.

DEMKO 17 ATEX 1923X Rev. 2

[15]

Description of Product

These motors are total enclosed non-ventilated permanent magnet, servo specialty motors. The motors have a three-phase connection wound field. They are intended to be controlled by a pulse width modulated (PWM) variable frequency drive. The speed of the motor is varied by changing the frequency of the power supplied. The drive frequency and voltage are changed by rapid pulse width modulating of a bus voltage. The current waveform used is sinusoidal. The motors are rated for a 320 max or 640 max bus voltages.

The motors are brushless designs employing a feedback device that controls the motor rotation and shaft position. The motors are temperature limited with over temperature (OTL) devices installed in the windings. The OTL is an automatic resetting device and should be connected directly into a power disabling or latched (locked-out) type circuit that requires manual resetting.

An installation manual is provided specifying the power supply requirements, the PWM controller output and performance characteristics required, the resolver ratings, thermostat ratings and connections and the motor performance curves when held within the specified limits of operation.

<u>M4</u>	<u>3</u>	<u>2</u>	-	<u>N</u>	<u>N</u>	<u>N</u>	<u>0</u>	-	<u>B</u>	<u>G</u>	<u>0</u>	<u>8</u>	<u>1A</u>
I	II	III		IV	V	VI	VII		VIII	IX	X	XI	XII

I – Basic Designation

M4 – Square motor

II – Motor Frame

Given as 3, 4, or 6

III – Number of magnets (stack length)

Given as 1, 2, 3, 4, or 5

IV – Designation of speed

Given as a letter

V – Output Shaft and Flange Dimensions

Given as a letter

VI – Magnet Material

Given as a letter

VII – Brake

Given as a letter; 0 (zero) designates without brake

VIII – Explosion Protected by Dust protected Enclosure and Winding Voltage

Given as B or C

IX – Feedback Device

Given as a letter or number; 0 (zero) designates without feedback device

X – Secondary Feedback Device

Given as a letter; 0 (zero) designates without feedback device

XI – Connection method

Given as a letter or number

XII – (Optional) Factory Assigned Options

Two characters, given as a combination of letters or numbers

Temperature range

The ambient temperature range is -25°C to +40°C.

Accredited by DANAK under registration number 7011 to certification of products.



[13]

[14]

Schedule

EU-TYPE EXAMINATION CERTIFICATE No.

DEMKO 17 ATEX 1923X Rev. 2

Electrical data

M43, M44, and M46 servo motors vital rated values:

	M43	M44	M46
Max Continuous HP	1.29	2.21	5.11
Max. rated rpm at continuous operation	5500	4500	3500
Voltage rating, V	230 or 460	230 or 460	230 or 460
Max. current, continuous, A	5.7	8.7	23.5
Duty rating	continuous	continuous	continuous
	or 5 seconds on 55 seconds off		

[16]

Descriptive Documents

The scheduled drawings are listed in the report no. provided under item no. [8] on page 1 of this EU-Type Examination Certificate.

[17]

Specific conditions of use:

- Motors are manufactured with permanently connected unterminated conductors and therefore marked with the X to indicate the need for appropriate protection of the free end of the conductors. The supplied lead seal is not sufficient for the protection method for the free end of the conductors. An ATEX/IECEx conduit sealing device(s) complying with the requirements of EN IEC 60079-0:2018/IEC 60079-0 Ed. 7 and EN 60079-31:2014/IEC 60079-31 Ed. 3 shall be supplied by the end user.
- Ambient range is -25°C to +40°C for all applicable motor models.
- The motors must be excited with 3-phase sinusoidal currents in proper relationship to the motor's generated voltage of back electromotive force at each rotor position. A pulse-width-modulated (PWM) current amplitude, frequency and phase for operation of the rotor within its specification. The PWM switching frequency is specified at a minimum of 3 kHz.

[18]

Essential Health and Safety Requirements

The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.

Additional information



The trademark **ELWOOD MOTORS** will be used as the company identifier on the marking label.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.

Accredited by DANAK under registration number 7011 to certification of products.

